

4Kw Single Phase Thyristor

Page 1 of 2

Description


The DIN Rail mounting Power Controller TCD1-4 is suitable for providing control of electric heating loads from an analogue signal. Applications include electric heating coils, heating cables and electric furnaces. The units utilise solid-state switching with "zero crossing technology" to provide accurate switching control. All items are provided with an alarm output for over temperature protection and LED Indication of Output ON. The TCD1-4 is designed to mount on DIN rail.

Technical Specification

Input:	Selectable 0...10V, 0...5V, 2...10V, 4...20mA		
Power Supply:	24Vac/dc +/-10% (self-powered option)		
Alarm Output:	24V alarm output drops to 0V on alarm for connecting to external relay		
Max Heater Duty:	4Kw		
Rated Load:	Load@220V	Dissipated Heat	
	18A	22W	
Rated Supply:	220...255Vac, 50/60Hz		
LED Indication:	ON when output is on.		
Terminals	Rising cage terminals		
Ambient Temp:	Maximum 45°C without de-rating		
Dimensions:	95 x 94 x 80 mm Control Supply		
Country of Origin:	United Kingdom		

Order Codes

TCD1-4	4Kw Single Phase Thyristor Power Controller
TCD1-4-SP	Self-powered Option Factory fitted



Features

- Selectable Control Input
- 4Kw Heater Duty
- Over Temperature Protection
- 24Vac/dc or self-powered options
- LED Indication
- DIN Rail Mounting



Installation and Configuration

The TCD1-4 is suitable mounting on DIN Rail and must be installed with the heatsink cooling ins orientated vertically. There should be a minimum of 100mm vertically between units.

Electrical Installation

Installation must be carried out by a suitably trained electrician, and in accordance with the relevant statutory regulations.

Load Supply and Back-up Protection

High speed fuses or miniature circuit breakers should be utilised to provide back-up protection to the switching devices.

It is recommended that a load disconnect switch and a contactor are installed in the load supply.

Control Supply

The unit is supplied as standard with the requirement for a 24Vac/dc auxiliary power supply. There is the option of having a transformer fitted to the unit so that the unit is self-powered without the need for an auxiliary supply. If this option is used then it is essential to connect your neutral to the neutral terminal.

See wiring for details. The control supply common is linked to the 0-10V Input Signal common. Screened cable should be used for connections to BMS Controllers, where possible the cable screen should be connected to a functional earth and at one end only to avoid earth loops.

Cycle Time & Signal Rescaling

The unit is supplied with the cycle time set to minimum. An on-board potentiometer is provided to facilitate adjustment of the cycle time in the range of 5 to 60 seconds.

Maximum Heating Load

The power rating of the units are given as a guide. The maximum current (which is dependant on the actual supply voltage and heating load) must not be exceeded.

4Kw Single Phase Thyristor

Operation

The TCD1-4 has been designed to control electric heating loads in proportion to the incoming, selectable analogue signal. Control of the load is facilitated by the use of solid-state semiconductor devices and feature zero crossing point switching of the AC load which virtually eliminates RFI problems.

Caution

In normal operation the heatsink surface can exceed 90°C. Dangerous voltages exist on the PCB and particular care should be taken. The TCD1-4 must be installed in accordance with the relevant statutory regulations and installation must be carried out by an experienced and fully qualified engineer.

Ventilation

The TCD1-4 is suitable for use up to a maximum ambient temperature of 45°C which should not be exceeded. If necessary, enclosures or control panels should be ventilated with a cooling fan, particularly if the unit is being used to run at full power to provide forced cool air movement over the heatsink.

Over Temperature Monitoring

The TCD1-4 is provide with an electronic thermal cut-out fitted to the heatsink to protect against over temperature. The unit will switch off the load if the heatsink temperature exceeds 95°C and will automatically reconnect the load once the heatsink temperature has dropped below 85°C. Upon switching, the alarm output from the control PCB will change from 24V to 0V.


The heatsink temperature will not reach 95°C under normal operating conditions. However, this might occur if the ambient temperature exceeds 45°C.

Jumper Settings


Voltage Inputs




I/V Jumper




0...10Vdc



0...5Vdc



2...10Vdc




1...5Vdc


Current Inputs




I/V Jumper




4...20mA



2...10mA




0...20mA



0...10mA

Wiring

I / V Jumper



Mode Input Jumper

